

**PORT RCC PHYSICAL SECURITY PROJECT
ENG. 19.013**

ADDENDUM NO. 3

**THURSDAY, JULY 19, 2019
Pages total - 1**

GENERAL

1. Attached is a copy of the Mandatory Prebid Meeting Sign-in Sheet. Only those prime contractors in attendance will be allowed to bid on this project.
2. Both the Entry Guard Arm to the parking lot and the Rolling Grill at the entrance to the parking garage are to be controlled with handheld programmable “clickers”. The Guard Arm on the exit side is to open upon approach to the exit. Contractor to provide Twenty (20) two-button remotes. Contractor to program the remotes such the first button opens the Entry Guard Arm at the parking lot and the second button opens the Rolling Grill at the parking garage. A push button access controller on bollard is not required unless it is integral to the operation of the entire Guard Arm System. Click2enter access is still required on both the Guard Arms and the Rolling Grill.
3. Fire Sprinkler modification will be required at two locations, not one. Piping will also need to be modified just South of the main entry doors where new fencing will interfere with drain line location.
4. Contractor to coordinate in advance with Sprinkler Company to determine if a Fire Watch will be required while modification to the sprinkler piping is required. If so, plan and price accordingly.
5. All parking curbs are required to be removed and reinstalled further into the parking garage to keep cars from hitting the new security fencing. Exact distance to be relocated to be determined in the field. If Contractor feels the curbs can be relocated without damage, then Contractor has option to relocate existing curbs. If not, then purchase and install new curbs. Existing curbs are to be removed regardless.
6. The Project Specific M/WBE participation goal for this project is established at 35%.

PLANS

1. Replace Notice to Contractors page with the attached revised sheet. This is to provide clarification on the anticipated bid date.

Attachment #1 – Mandatory Prebid Meeting Sign in Sheet
Attachment #2 – Revised Notice to Contractors

PRE-BID CONFERENCE -MANDATORY

Project: Port Physical Security Project - ENG. 19.013

Date: July 16, 2019

Time: 2:00 P.M.

PLEASE PRINT OR WRITE LEGIBLY
ATTENDANCE LIST

NAME	ORGANIZATION	TEL	EMAIL
1. MELVIN DENNIS	DENNIS CONSULT	318 8651880	dennis@ATT.NET
2. John M. Hunter	Delta Specialty Contractors	318-2444	Hunter.jm@delta.net
3. Charney Horton	SNA Contracting, LLC	318-918-0032	charney@snacontracting.com
4. TUAN NGUYEN	KAN Contracting	318-560-7727	tuan.kan@att.net
5. Tyler Cormaux	Port	318 524 2276	tylerc@portsb.com
6. Denny Malone	(Port)	318.524.2272	denny@portsb.com
7. KEVIN BRYAN	KBA	318.673.9980	KEVIN@KEVINBRYANARCHITECT.COM
8. Rick Nance	Port	318-426-0877	Rick@portsb.com
10.			
11.			
12.			
13.			
14.			
15.			
16.			
17.			

NOTICE TO CONTRACTORS

Sealed bids for the construction of the following project will be received by the Caddo-Bossier Parishes Port Commission (Contracting Agency), at The Regional Commerce Center, 6000 Doug Attaway Blvd., Shreveport, LA 71115, until 2:00 PM July 30, 2019, at which time and place bids will be publicly opened and read. No bids will be received after **2:00 PM**.

A **mandatory pre-bid conference** will be held at, at The Regional Commerce Center, 6000 Doug Attaway Blvd., Shreveport, LA 71115 at 2:00 PM on July 16, 2019.

PROJECT:	PORT RCC PHYSICAL SECURITY PROJECT Proj.No. ENG.19.013
LOCATED IN:	CADDO PARISH
TYPE OF CONSTRUCTION:	FENCING AND ACCESS CONTROL
CONTRACTING AGENCY:	CADDO-BOSSIER PARISHES PORT COMMISSION 6000 DOUG ATTAWAY BLVD. SHREVEPORT, LOUISIANA 71115
ESTIMATED COST:	\$175,000.00
PROPOSAL GUARANTY:	5% OF THE AMOUNT PROPOSAL
	PAYABLE TO CADDO-BOSSIER PARISHES PORT COMMISSION
ARCHITECT:	KEVIN BRYAN ARCHITECT, L.L.C. 712 TEXAS STREET SHREVEPORT, LA 71101 (318)-673-9980

Proposals must be submitted on the forms provided by the Contracting Agency, must be prepared in accordance with the DOTD General Conditions, along with any Supplemental Conditions or Special Provisions, and must include all the information required by the Louisiana Uniform Public Work Bid Form. Drawings and Specifications are available from the Architect and will not be issued later than 24 hours prior to the time set for opening the bids. Each bid shall include a proposal guaranty in an amount not less than specified above.

Complete Drawings and Specifications are also offered through BidExpress, and may be electronically viewed and submitted at www.bidexpress.com